



Public Input No. 217-NFPA 101-2018 [Section No. 14.2.2.2.4]

~~14.2.2.2.4 * – Classroom Door Locking to Prevent Unwanted Entry.~~

~~Classroom doors shall be permitted to be locked to prevent unwanted entry provided that the locking means is approved and all of the following conditions are met:~~

- ~~(1) The locking means shall be capable of being engaged without opening the door.~~
- ~~(2) The unlocking and unlatching from the classroom side of the door can be accomplished without the use of a key, tool, or special knowledge or effort.~~
- ~~(3) The releasing mechanism shall open the door leaf with not more than one releasing operation.~~
- ~~(4) The releasing mechanism for unlocking and unlatching shall be located at a height not less than 34 in. (865 mm) and not exceeding 48 in. (1220 mm) above the finished floor.~~
- ~~(5) Locks, if remotely engaged, shall be unlockable from the classroom side of the door without the use of a key, tool, or special knowledge or effort.~~
- ~~(6) The door shall be capable of being unlocked and opened from outside the room with the necessary key or other credential.~~
- ~~(7) The locking means shall not modify the door closer, panic hardware, or fire exit hardware.~~
- ~~(8) Modifications to fire door assemblies, including door hardware, shall be in accordance with NFPA 80.~~
- ~~(9) The emergency action plan, required by 14.7.1 , shall address the use of the locking and unlocking means from within and outside the room.~~
- ~~(10) Staff shall be drilled in the engagement and release of the locking means, from within and outside the room, as part of the emergency egress drills required by 14.7.2 .~~

Statement of Problem and Substantiation for Public Input

This proposal is based on the acceptance of the new section 7.2.1.6.4 Emergency Locking Systems.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
<u>Public Input No. 218-NFPA 101-2018 [New Section after 14.2.2.3.3]</u>	
<u>Public Input No. 216-NFPA 101-2018 [New Section after 7.2.1.6.3]</u>	

Submitter Information Verification

Submitter Full Name: Keith Pardoe
Organization: Pardoe Consulting LLC
Street Address:
City:
State:
Zip:
Submittal Date: Mon Jun 18 10:57:32 EDT 2018

Committee: SAF-END

Copyright Assignment

I, Keith Pardoe, hereby irrevocably grant and assign to the National Fire Protection Association (NFPA) all and full rights in copyright in this Public Input (including both the Proposed Change and the Statement of Problem and Substantiation). I understand and intend that I acquire no rights, including rights as a joint author, in any publication of the NFPA in which this Public Input in this or another similar or derivative form is used. I hereby warrant that I am the author of this Public Input and that I have full power and authority to enter into this copyright assignment.



By checking this box I affirm that I am Keith Pardoe, and I agree to be legally bound by the above Copyright Assignment and the terms and conditions contained therein. I understand and intend that, by checking this box, I am creating an electronic signature that will, upon my submission of this form, have the same legal force and effect as a handwritten signature